

Site Specific Design, Inc.

1704 Rockwell Road
Abington, PA 19001



215-887-3730

Invoice

Date	Invoice #
11/8/2024	78001

Bill To	Ship To
Upper Providence Township Attn: Kevin Matson, Sewer Authority 935 N. Providence Road Media, PA 19063	Upper Providence Township 935 N Providence Road 610-566-5376 Media, PA 19063

Cust. PO #	Terms	Rep	Ship Date	Ship Via		Project
	Net 30	PB	11/8/2024			
Qty	Item Code	Description			Price Each	Amount
		Repair DH425003 Joseph Talento (Upper Prov) 271 Steeplechase Dr Media, Pennsylvania 19063-1956 Date of service 11/8/24 Technician Pat Brady Arrived on site and found pump DH425003 not in alarm but the contactor inside the panel was humming very loud took meter readings all readings were correct. I made sure all the wires were tightened in the panel still kept humming changed out the contactor the noise stopped pumped down and shut off at 5.9 amps pump is running correctly			OK TO PAY KEVIN MATSON, PE, OPERATIONS MANAGER  12/10/2024	
1	Service/Ins 7104	Service Call & Inspection Fee PA 1476P01 Contactor Control Clip Motor 220v/240v (Alarm Panels & 2000 Series flat control bracket)			170.00 66.0025	170.00 66.00

All material remains the property of Site Specific Design until final payment.

Subtotal	\$236.00
Sales Tax (0.0%)	\$0.00
Total	\$236.00
Payments/Credits	\$0.00
Total Due	\$236.00

Returned checks will incur a \$25.00 surcharge. If at any time your account runs past due, all shipments may be held pending.